

FIELD SERVICE REPORT

6-03-2019

Item Description	Kast N°	Contract Nr		
ZB-S	208-110-035 NV1+2			
Unit Install date	19-05-2001	Battery Install date	6-03-2019	
Battery Brand	UPS	Battery Type	12-150MRX	Nr.of Bats 18

Customer:		Site Information:	Client ref:	
HAN Facilitaire zaken		Site: HAN		
Street: Postbus 5171		Street: Ruitenberglaan 29		
PC: NL 6802 ED	City: Arnhem	PC: NL 5836 CC	City: Arnhem	
Customer contact: Laurens Holtrigter		Site contact:		
Customer email: laurens.holtrigter@han.nl		Tel:		Mobile:
Customer PO:				

Reason for call / intervention:

Batterijset vervangen

Problems Found / solved

Batterijset vervangen

Follow ups / Remarks:


Done : Maintenance Commissioned Checkup Installation New unit installed Installation Works

Replaced : Set of Batteries Defective Parts

To be done : Parts to be replaced Batterie(s) to be replaced Make a quotation

Part Number	Description	QTY	Labor Expenses		code
	UPS 12-150MRX	18	Service work 1 (h)	2:00 2:00	
			Service work 2 (h)		
			Service work 3 (h)		
			Waiting time (h)		13
			Off Hours work (h)		
			Travel time (h)	2:00 2:00	14
			Kilometers (km)	148 148	
			Start Time:	11:00	
			Stop Time:	13:00	

Date	Service Engineer 1	Signature
6-03-2019	Bert Eilerts	
	Service Engineer 2	
		Name:

System status 

NORMAL

Warning

Alarm

System 000