

CERTIFICATE OF CONFORMITY – FOAM CONCENTRATES

Certificate of conformity reference number: **KB 133/17**

Test specification: **EN 1568-1 : 2008, EN 1568-2 : 2008, EN 1568-3: 2008, EN 1568-4: 2008**
except for clause 11 – container marking, see the information below

Test report no.: **20170920/Eau 92**

Requested by: **EAU et FEU SA, Zone industrielle Sud-Est, Rue Aioys Senefelder, B.P.1008**
51683 Reims Cedex 2, France

Manufacturer: **EAU et FEU SA, Zone industrielle Sud-Est, Rue Aioys Senefelder, B.P.1008**
51683 Reims Cedex 2, France

Name of the fire
extinguishing medium: **FOAM MASTER 3F 3/3 SP**

Grade of foam concentrate: **Synthetic alcohol resistant foam concentrate (S-AR)**
according to annex A EN 1568

Test fire performance: **Extinguishing performance and burn-back resistance:**

- Medium expansion foam according to EN 1568-1 (3%)
with potable water / with simulated sea water:
The requirements for medium expansion foam are met.
- High expansion foam according to EN 1568-2 (3%)
with potable water / with simulated sea water:
The requirements for high expansion foam are met.
- Low expansion foam according to EN 1568-3 (3%)
with potable water / with simulated sea water: **I A / I A**
- Low expansion foam according to EN 1568-4 (3%) (alcohol resistant foam concentrate)
with potable water / with simulated sea water: **I A / I A (acetone)**
with potable water / with simulated sea water: **II B / II A (isopropanol)**

Freezing point: **- 12 °C**

Notes: **The information according to clause 11 of EN 1568 for container marking shall be stated on the packing or on the transport container. Pseudo plastic foam concentrate. This concentrate can require special proportioning equipment. Clause 9.2 of the EN 1568 can not be evaluated due to the high stability of the foam.**

Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for foam concentrates which correspond to the submitted test samples and to the confirmed documents.

Certificates of conformity of fire extinguishers are solely valid in conjunction with the fire extinguishing medium the type test of the fire extinguisher has been done with.

This certificate of conformity does not include surveillance.

12 September 2017


Grad. Eng. Jürgen Dittrich
Laboratory Manager

MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268
Steuernummer: 220/114/03364
USt-IdNr. DE291271296

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
IBAN DE68 870520003115024672
BIC WELADED1FGX

