

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : APPARTEMENTEN
CESAR FRANCKSTRAAT 4
7604JG ALMELO

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
31-08-2020 11:19		LIFT STOPPED	Lift staat stil	Schachtdeurgrendel	No	No	305 (KBO)	2:16	0:26

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : LYCEUM DE GRUNDEL
GRUNDELLAAN 36
7552EP HENGELLO (OV)

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
05-03-2019 17:37		LIFT MAKING NOISE	Lift staat stil	Besturingssch. Hefpl.	Yes	No	268 (BOE)	14:23	1:15
06-02-2020 09:49		DOOR DOES NOT CLOSE	Lift staat stil	Besturingssch. Hefpl.	No	No	268 (BOE)	1:41	1:30
03-03-2020 10:45		DOOR DOES NOT CLOSE	Performance afwijking	Schachtdeurmachine mechanisch	No	No	192 (GBI)	0:30	2:30
14-08-2020 11:29		DOOR MAKING NOISE	Performance afwijking	Schachtdeursluite	No	No	305 (KBO)	0:29	1:00
24-09-2020 09:08		DOOR DOES NOT CLOSE	Performance afwijking	Schachtdeursluite	No	No	1499 (RHU)	5:33	0:51
08-10-2020 12:42		DOOR DOES NOT CLOSE	Lift staat stil	Electrische aansluiting schacht(deur)	No	No	305 (KBO)	2:47	1:10

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : Twents Carmel College
LELIESTRAAT 1
7572VD OLDENZAAL

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
21-06-2019 07:56	LIFT STOPPED	Lift staat stil	Storing microprocessor	No	Yes	2382 (HNO)	4:57	2:53
21-06-2019 07:56	LIFT STOPPED	Lift staat stil	Inspektie	No	No	192 (GBI)	3:27	4:32
12-06-2020 11:50	CABIN LIGHT DEFECT	Klein defect	(Nood)verlichting liftkooi	No	No	1499 (RHU)	68:10	1:30

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : TWENTS CARMEL COLLEGE
LYCEUMSTRAAT 36
7572C OLDENZAAL

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
22-05-2019 12:34	LIFT STOPPED	Lift staat stil	Grendelcontact schachtdeur	No	No	2802 (ARI)	1:39	1:39
22-05-2019 12:34	LIFT STOPPED	Lift staat stil	Grendelcontact schachtdeur	No	Yes	268 (BOE)	1:25	1:31
17-06-2020 12:56	DOOR OPENS AND CLOSES	Lift staat stil	Schachtdeur(paneel)	No	No	305 (KBO)	2:33	1:01
04-09-2020 11:39	PROBLEM UNKNOWN	Klein defect	Schachtdeursluite	No	No	305 (KBO)	3:06	0:25
16-09-2020 09:41	LIFT STOPPED	Lift staat stil	Schachtdeursluite	No	No	1499 (RHU)	1:11	1:26

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : TWENTS CARMEL COLLEGE
POSTKAMPSTRAAT 2
7573C OLDENZAAL

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : TWENTS CARMEL COLLEGE
POSTKAMPSTRAAT 2
7573C OLDENZAAL

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
25-09-2020 13:00		CABIN LIGHT DEFECT	Klein defect	(Nood)verlichting liftkooi	No	No	1499 (RHU)	67:02	0:26
12-11-2020 09:00		DOOR OPENS AND CLOSES	Klein defect	Kooideurleidslof	No	No	3714 (HWE)	3:45	0:30

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building :

Contract : C A5325

SPORTLAAN DRIEN 1-6
7552HA HENGELLO (OV)

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
24-09-2020 11:41	TRAPPED PASSENGER	Opsluiting/Veiligheids in geding	Hoofdzekering	No	No	305 (KBO)	0:07	0:42

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE DE THIJ
THIJLAAN30
7576ZB OLDENZAAL

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE
DEKEN HOOIJMANSINGEL 1
7141EA GROENLO

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
27-05-2019 11:33	LIFT STOPPED AFTER TRAPPED PASSENGER	Opsluiting/Veiligheid in geding	Electrische aansluiting liftkooi	No	No	2802 (ARI)	2:32	1:13
06-06-2019 09:38	LIFT STOPPED	Lift staat stil	Electrische aansluiting liftkooi	No	No	2802 (ARI)	5:44	1:10
13-09-2019 15:36	PROBLEM UNKNOWN	Klein defect	Leidsloffen/-rollen liftkooi	Yes	No	2802 (ARI)	67:55	1:27

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE
DEKEN HOOIJMANSINGEL 1
7141EA GROENLO

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
13-09-2019 15:34	LIFT MAKING NOISE	Klein defect	Centrering liftkooimeubel	Yes	No	2802 (ARI)	64:21	0:33
13-09-2019 15:34	LIFT MAKING NOISE	Klein defect	Centrering liftkooimeubel	Yes	Yes	268 (BOE)	64:26	0:30
30-10-2019 15:34	PROBLEM UNKNOWN	Klein defect	Kooideur(paneel)	No	No	268 (BOE)	19:36	0:20
24-11-2020 14:28	LIFT STOPPED	Lift staat stil	Inspektie	No	No	2802 (ARI)	17:32	1:22
30-11-2020 08:46	LIFT STOPPED AFTER TRAPPED PASSENGER	Lift staat stil	Inspektie	No	No	2802 (ARI)	6:52	0:58
01-12-2020 13:37	LIFT STOPPED AFTER TRAPPED PASSENGER	Opsluiting/Veiligheid in geding	Electrische aansluiting liftkooi	No	No	3714 (HWE)	20:23	3:30
08-12-2020 08:08	LIFT STOPPED AFTER TRAPPED PASSENGER	Lift staat stil	Buigzame stuurstroomkabels	No	No	790 (HFI)	23:52	5:46
08-12-2020 08:08	LIFT STOPPED AFTER TRAPPED PASSENGER	Lift staat stil	Buigzame stuurstroomkabels	No	Yes	2802 (ARI)	27:30	1:42

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : BONHOEFFER COLLEGE
BRUGGERTSTRAAT 60
7545AX ENSCHEDE

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : S.G MARIANUM
DR. ARIENSTRAAT 3
7131ER LICHTENVOORDE

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
16-04-2019 14:23	DIFFERENCE OF LEVEL	Performance afwijking	Rem	No	No	2802 (ARI)	19:27	2:00
18-04-2019 10:52	PROBLEM UNKNOWN	Performance afwijking	Schachtdeurgrendel	No	No	3714 (HWE)	2:07	1:00
15-10-2019 10:02	LIFT STOPPED AFTER TRAPPED PASSENGER	Lift staat stil	Inspektie	No	Yes	2802 (ARI)	0:45-	1:39
15-10-2019 10:02	LIFT STOPPED AFTER TRAPPED PASSENGER	Lift staat stil	Inspektie	No	No	268 (BOE)	-2:02-	2:30
04-09-2020 14:47	CABIN LIGHT DEFECT	Klein defect	Noodvoeding machinekamer	Yes	No	366 (BOV)	68:27	0:59

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building :

Contract : C A5325

GROEN VAN PRINSTERERSINGEL 49
2805TD GOUDA

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
25-03-2020 08:41	PROBLEM UNKNOWN	Performance afwijking	Kooidrukknoppen	No	No	1619 (KAI)	4:50	3:46
26-05-2020 09:34	LIFT STOPPED	Lift staat stil	Stuurstroomzekering	No	No	1634 (MKA)	3:27	0:50

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building :

Contract : C A5325

JOHN MOTTSTRAAT 2-4
2806HP GOUDA

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
10-01-2019 11:29	DIFFERENCE OF LEVEL	Performance afwijking	Vanen/magneten schacht	Yes	No	1634 (MKA)	20:18	2:08
26-09-2019 12:32	LIFT STOPPED	Lift staat stil		No	No	3860 (YZW)	1:50	2:24
26-09-2019 12:32	LIFT STOPPED	Lift staat stil	Transformator	No	No	3860 (YZW)	19:27	4:26
26-09-2019 12:32	LIFT STOPPED	Lift staat stil	Transformator	No	Yes	221 (DWA)	19:28	4:15
19-11-2019 17:15	DIFFERENCE OF LEVEL	Performance afwijking	Storing microprocessor	Yes	No	3860 (YZW)	20:29	0:29
15-01-2020 14:45	DOOR DOES NOT CLOSE	Lift staat stil	Noodeinschakelaar	Yes	No	3860 (YZW)	21:23	1:20
19-02-2020 15:07	DOOR DOES NOT OPEN	Lift staat stil	Inspectie	No	No	3860 (YZW)	18:51	1:10
06-05-2020 08:10	LIFT STOPPED	Lift staat stil	Schachtdeur(paneel)	No	No	1634 (MKA)	2:09	1:03
12-11-2020 10:19	LIFT STOPPED	Lift staat stil	Schachtdrukknop	No	No	1634 (MKA)	2:56	2:09

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : ETTY HILLESUM
HERMAN BOERHAVELAAN 1
7415ES DEVENTER

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
19-11-2019 12:50	LIFT STOPPED	Lift staat stil	Storing microprocessor	No	No	2169 (WVM)	2:18	1:22
27-01-2020 08:20	LIFT STOPPED	Lift staat stil	Besturingssoftware	No	No	192 (GBI)	0:25	0:45
28-01-2020 07:50	LIFT STOPPED	Lift staat stil	Electrische aansluiting schacht(deur)	No	No	931 (JGE)	3:13	1:39
29-01-2020 14:37	LIFT STOPPED	Lift staat stil	Grendelcontact schachtdeur	No	Yes	2169 (WVM)	24:34	1:19
29-01-2020 14:37	LIFT STOPPED	Lift staat stil	Schachtdeurcontact	No	No	3714 (HWE)	17:23	4:30
31-01-2020 09:12	LIFT STOPPED	Lift staat stil	Inspektie	No	No	192 (GBI)	0:58	3:26
31-01-2020 09:12	LIFT STOPPED	Lift staat stil	Noodvoeding machinekamer	No	Yes	2382 (HNO)	0:54	1:41
03-02-2020 08:19	LIFT STOPPED	Lift staat stil	Besturingssoftware	No	No	192 (GBI)	1:41	1:00
26-03-2020 12:05	PROBLEM UNKNOWN	Klein defect	Verdiepingsschakelaar	Yes	No	2802 (ARI)	19:55	1:58

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building :

Contract : C A5325

SCHOONSTRAAT 34
5384AP HEESCH

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
20-01-2020 08:33	LIFT STOPPED	Lift staat stil	Besturingssoftware	No	No	1651 (EKE)	4:10	0:29
23-01-2020 12:52	LIFT STOPPED	Lift staat stil	Grendelcontact schachtdeur	No	No	706 (WVE)	0:32	1:35

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : Titus Brandsma Lyceum
MOLENSTRAAT 30
5341G OSS

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
15-01-2019 09:01	LIFT STOPPED	Lift staat stil	Schachtdeurcontact	No	No	1617 (GKA)	3:47	2:01

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : Titus Brandsma Lyceum
MOLENSTRAAT 30
5341G OSS

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : RUIVERT SCHOLENGEMEENSCHAP DE
RUIVERT DE 5
5342C OSS

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
06-02-2019 09:44	DOOR CLOSES TOO FAST	Performance afwijking	Kooidrukknoppen	No	No	706 (WVE)	3:01	2:15
16-05-2019 12:53	LIFT STOPPED	Lift staat stil	Schachtdeurgrendel	No	No	53 (ABR)	2:52	1:00
14-06-2019 09:56	PROBLEM UNKNOWN	Performance afwijking	Standaanwijzer schacht	No	No	1607 (LJO)	1:38	1:59
02-03-2020 10:58	LIFT STOPPED	Lift staat stil	Electronisch component	No	No	2490 (HOZ)	3:52	0:40

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building :

Contract : C A5325

VERDISTRAAT 75
5343VC OSS

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
01-07-2019 08:50	LIFT STOPPED	Lift staat stil	Besturingssch. Hefpl.	No	No	2490 (HOZ)	1:26	0:26

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : ETTY HILLESUM LYCEUM
STORMINKSTRAAT
7418G DEVENTER

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
06-05-2019 20:28	LIFT FALTERS	Klein defect	Inspektie	Yes	No	192 (GBI)	11:32	2:00
14-05-2019 11:28	PROBLEM UNKNOWN	Performance afwijking	Inspektie	No	No	192 (GBI)	1:14	1:45
17-09-2019 16:38	DIFFERENCE OF LEVEL	Performance afwijking	Vanen/magneten schacht	Yes	No	3714 (HWE)	15:22	1:59
10-03-2020 08:02	LIFT STOPPED	Lift staat stil	Schachtdeurcontact	No	No	192 (GBI)	0:02-	1:04

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : ETTY HILLESUM
VLIET HET 1
7414AR DEVENTER

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
17-11-2020 09:30	DOOR DOES NOT CLOSE	Performance afwijking	Schachtdeurrollen	No	No	366 (BOV)	1:04	0:54

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : MARKE ZUID DE
LUDGERSTRAAT 1
7415DV DEVENTER

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
17-05-2019 07:16	LIFT STOPPED AFTER TRAPPED PASSENGER	Lift staat stil	Schachtdeur(paneel)	No	No	3714 (HWE)	0:44	1:29
14-08-2019 13:07	PROBLEM UNKNOWN	Performance afwijking	Assistentie klant	No	No	192 (GBI)	3:35	1:30
03-09-2019 15:45	PROBLEM UNKNOWN	Klein defect	Electronisch component	Yes	No	192 (GBI)	16:15	1:42
13-09-2019 10:08	DOOR DOES NOT CLOSE	Klein defect	Inspectie	No	No	192 (GBI)	1:51	2:41

UNIT CALLBACK INQUIRY

From 01-01-2019 to 24-02-2021

24/02/2021

Version 6

Building : CARMEL COLLEGE
DR. ARIENSTRAAT 1
7131EP LICHTENVOORDE

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
07-05-2019 13:00	LIFT STOPPED	Lift staat stil	Motorbeveiliging	No	No	268 (BOE)	1:17	1:30
05-06-2019 12:03	CAR BUTTON DEFECT	Klein defect	Kooidrukknoppen	No	No	2802 (ARI)	22:51	0:30
06-07-2020 10:15	PROBLEM UNKNOWN	Klein defect	Vanen/magneten schacht	Yes	Yes	3714 (HWE)	25:45	1:30
06-07-2020 10:15	PROBLEM UNKNOWN	Klein defect	Vanen/magneten schacht	Yes	No	1930 (ML)	21:45	5:29

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE
DR. ARIENSTRAAT 1
7131EP LICHTENVOORDE

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE
DR. ARIENSTRAAT 1
7131EP LICHTENVOORDE

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : SCHOOL
VLIERSTRAAT 75
7544G ENSCHEDE

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
01-04-2019 09:12	DOOR DOES NOT CLOSE	Klein defect	Veiligheidslijst electrisch	No	No	268 (BOE)	1:25	2:08
22-08-2019 09:36	DOOR OPENS AND CLOSES	Klein defect	Terugloopcontact kooideur	No	No	2382 (HNO)	1:26	0:36

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building :

Contract : C A5325

WENDELING 59
7824TA EMMEN

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
08-11-2019 11:18	LIFT STOPPED	Lift staat stil	Storing microprocessor	No	No	1608 (WJ)	3:35	1:37
20-01-2021 10:22	LIFT MAKING NOISE	Performance afwijking	Relais(onderdelen)	No	No	1608 (WJ)	0:47	0:21

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building :

Contract : C A5325

WENDELING 59
7824TA EMMEN

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE
ZWOLSESTRAAT 57
8101AB RAALTE

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
14-02-2019 10:48	LIFT STOPPED	Lift staat stil	Voor niets geweest	No	No	2169 (WVM)	1:12	0:30
04-06-2020 13:19	PROBLEM UNKNOWN	Klein defect	Besturingssch. Hefpl.	No	No	1499 (RHU)	1:56	1:15
02-10-2020 10:06	LIFT STOPPED	Lift staat stil	Assistentie klant	No	No	1499 (RHU)	3:58	0:53

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : MONDRIAAN COLLEGE - HET HOOGHUIS
MONDRIAANLAAN 6
5342C OSS

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
06-07-2020 08:34	DIFFERENCE OF LEVEL	Lift staat stil	Vanen/magneten schacht	No	No	1952 (BRL)	5:47	1:09
09-02-2021 09:22	WATER DEMAGE/IN PIT	Lift staat stil	Assistentie klant	No	No	3205 (BOS)	2:37	0:46
10-02-2021 08:33	LIFT STOPPED	Lift staat stil	Hoofdzekering	No	No	3205 (BOS)	3:06	1:34

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : TWICKEL COLLEGE
WELEMANSTRAAT 51
7622HB BORNE

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
18-03-2019 09:22	LIFT FALTERS	Performance afwijking	Besturingssch. Hefpl.	No	No	268 (BOE)	1:03	1:05
10-04-2019 16:10	LIFT STOPPED	Lift staat stil	Besturingssch. Hefpl.	No	No	268 (BOE)	3:25	0:43
20-06-2019 13:17	DOOR DOES NOT CLOSE	Klein defect	Inspectie	No	No	192 (GBI)	19:13	2:30
06-07-2020 11:33	DOOR DOES NOT OPEN	Klein defect	Schachtdeursluite	No	No	1499 (RHU)	1:27	1:30
01-09-2020 09:48	DOOR DOES NOT CLOSE	Lift staat stil	Schachtdeursluite	No	No	3714 (HWE)	3:03	0:55
06-11-2020 14:49	LIFT STOPPED	Lift staat stil	Print defect	No	Yes	3714 (HWE)	67:04	0:59
06-11-2020 14:49	LIFT STOPPED	Lift staat stil	Electrische aansluiting schacht(deur)	No	No	305 (KBO)	65:11	3:02

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : TWICKEL COLLEGE
WOOLDERESWEG 130
7555LC HENGEL

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : SINGEL DE PRAKTIJKSCHOOL
EUTERPEHOF 20
5342C OSS

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : BONHOEFFER COLLEGE
BRUGGERTSTRAAT 60
7545AX ENSCHEDE

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
11-09-2019 08:43	LIFT STOPPED	Lift staat stil	Verdiepingsschakelaar	No	No	268 (BOE)	0:23	3:24

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE
HOFSTEDELAAN 4
8101AH RAALTE

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
16-04-2019 13:01	LIFT STOPPED	Lift staat stil	Inspektie	No	No	192 (GBI)	1:41	1:21
21-05-2019 15:40	LIFT STOPPED	Lift staat stil	Kooideurcontact	Yes	No	2694 (SSP)	16:03	2:17
04-11-2019 11:19	VOICELINK DOES NOT WORK	Performance afwijking	Remote Station	No	No	2169 (WVM)	20:41	3:08
04-11-2019 11:19	VOICELINK DOES NOT WORK	Performance afwijking	Remote Station	No	Yes	931 (JGE)	20:41	3:10
04-11-2019 11:19	VOICELINK DOES NOT WORK	Performance afwijking		No	No	2169 (WVM)	1:09	2:10
01-09-2020 13:42	LIFT STOPPED	Lift staat stil	Schachtdeursluite	No	No	2169 (WVM)	1:46	1:02
07-09-2020 16:44	DISPLAY DEFECT	Performance afwijking	Spreekverbinding REM	Yes	No	1499 (RHU)	39:18	1:26

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : TWENTS CARMEL COLLEGE
POSTKAMPSTRAAT 2
7573C OLDENZAAL

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building :

Contract : C A5325

RIJKSSTRAATWEG 24
9752AE HAREN

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
19-11-2020 15:54	TRAPPED PASSENGER	Opsluiting/Veiligheids in geding	Schachtdeurcontact	No	Yes	35 (MAS)	0:32	1:03
19-11-2020 15:54	TRAPPED PASSENGER	Opsluiting/Veiligheids in geding	Schachtdeurcontact	No	No	93 (JBA)	0:26	1:06

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CT STORK COLLEGE
FRE COHENSTRAAT 10
7556PB HENGELLO

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : TWENTS CARMEL COLLEGE
ORANJESTRAAT 2
7581EX LOSSER

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
28-10-2020 13:42	TRAPPED PASSENGER	Opsluiting/Veiligheids in geding	Schachtdeurcontact	No	Yes	3714 (HWE)	115:47	1:30
28-10-2020 13:42	TRAPPED PASSENGER	Opsluiting/Veiligheids in geding	Schachtdeurcontact	No	No	305 (KBO)	115:48	1:30
28-10-2020 13:42	TRAPPED PASSENGER	Opsluiting/Veiligheids in geding		No	No	305 (KBO)	0:48	1:06

UNIT CALLBACK INQUIRY

From 01-01-2019 to 24-02-2021

24/02/2021

Version 6

Building : MAARTENSCOLLEGE
HEMMENLAAN 2
9751NS HAREN

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
30-10-2019 13:58	LIFT STOPPED	Lift staat stil	Assistentie klant	No	No	2408 (FKN)	0:54	0:41
26-02-2020 09:26	LIFT STOPPED	Lift staat stil	Kooideurcontact	No	No	2408 (FKN)	4:42	2:22
26-02-2020 09:26	LIFT STOPPED	Lift staat stil	Kooideurcontact	No	Yes	2140 (WME)	5:42	1:22
08-09-2020 08:08	LIFT STOPPED	Lift staat stil	Besturingssoftware	No	No	3700 (NWE)	1:52	1:00
24-09-2020 15:33	LIFT STOPPED	Lift staat stil	Relais(onderdelen)	No	Yes	3700 (NWE)	17:30	2:56
24-09-2020 15:33	LIFT STOPPED	Lift staat stil	Relais(onderdelen)	No	No	2408 (FKN)	16:27	3:35

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : HET TWICKEL COLLEGE
SCHOPPENSTEDE 10
7491HK DELDEN

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE
FLORENS RADEWIJNSTRAAT 6
8101AB RAALTE

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
07-01-2020 11:06	LIFT STOPPED	Lift staat stil	Schachtdeur(paneel)	No	No	2169 (WVM)	1:53	1:11

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE
FLORENS RADEWIJNSTRAAT 6
8101AB RAALTE

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CARMEL COLLEGE DE THIJ
THIJLAAN30
7576ZB OLDENZAAL

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
14-03-2019 12:50	PROBLEM UNKNOWN	Performance afwijking	Schachtdruknop	No	No	268 (BOE)	19:10	1:30
27-09-2019 08:54	LIFT STOPPED	Lift staat stil	Schachtdeurleidslof	No	No	268 (BOE)	3:08	0:12
15-10-2020 09:50	ALARM DEFECT	Klein defect	REM-eenheid in machinekamer	Yes	No	1499 (RHU)	29:18	1:20
04-11-2020 13:26	HALL BUTTON DEFECT	Klein defect	Schachtdruknop	No	No	1499 (RHU)	1:20	0:54

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : BONHOEFFEROLLEGE
VAN DER WAALSLAAN 35
7535C ENSCHEDE

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
26-02-2019 09:22	LIFT STOPPED	Lift staat stil	Spanningsuitval	No	No	2382 (HNO)	0:54	0:12
02-09-2020 13:50	LIFT STOPPED	Lift staat stil	Noodremschakelaar liftkooi	No	No	305 (KBO)	1:58	0:42
15-09-2020 14:12	DOOR DOES NOT OPEN	Lift staat stil	Schachtdrukknop	Yes	No	2802 (ARI)	20:36	0:46

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : BONHOEFFEROLLEGE
VAN DER WAALSLAAN 35
7535C ENSCHEDE

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : BONHOEFFEROLLEGE
VAN DER WAALSLAAN 35
7535C ENSCHEDE

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : S.G MARIANUM
DR. ARIENSTRAAT 3
7131ER LICHTENVOORDE

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : MARKE NOORD DE
LEBUINUSLAAN 1
7415D DEVENTER

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
14-09-2020 10:15	LIFT STOPPED	Lift staat stil	Veiligheidslijst mechanisch	No	No	3714 (HWE)	4:30	0:30
15-09-2020 09:09	DOOR DOES NOT CLOSE	Lift staat stil	Verdiepingsschakelaar	No	No	1499 (RHU)	22:49	1:59

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : CANISIUS S.G.
SLOT 31
7608N ALMELO

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : BONHOEFFER COLLEGE
GEESSINKWEG 100
7544N ENSCHEDE

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : PIUS X COLLEGE
GRAAF OTTOSTRAAT 48
7461C RIJSSEN

Contract : C A5325

Date time	Caller	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
-----------	--------	--------	-----------------	---------	----------	---------	----------	----	----

Geen storingen in de rapporteringsperiode

UNIT CALLBACK INQUIRY

24/02/2021

From 01-01-2019 to 24-02-2021

Version 6

Building : MONDRIAAN COLLEGE
MONDRIAANLAAN 1
5342C OSS

Contract : C A5325

Date time	Reason	Perception Code	CB Code	Deferred	Assist.	Mechanic	T1	T2
11-02-2020 14:38	DOOR DOES NOT OPEN	Lift staat stil	Veiligheidslijst electrisch	No	No	1651 (EKE)	16:55	5:15