
Preparing Activity: NAVFAC

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2021

SECTION TABLE OF CONTENTS

DIVISION 23 - HEATING, VENTILATING, AND AIR CONDITIONING (HVAC)

SECTION 23 75 15

CUSTOM-PACKAGED, AIRCRAFT PRE-CONDITIONED AIR UNITS

02/20

PART 1 GENERAL

- 1.1 SUMMARY
- 1.2 RELATED SECTIONS
 - 1.2.1 Electrical
 - 1.2.2 Insulation
 - 1.2.3 Foam Fire Extinguishing System
 - 1.2.4 Field Painting
- 1.3 REFERENCES
- 1.4 SEQUENCING
- 1.5 SUBMITTALS
- 1.6 QUALITY CONTROL
 - 1.6.1 System Supplier's Qualifications
 - 1.6.2 Pre-Conditioned Air System Detail Drawings
 - 1.6.3 Certificate of Completion
- 1.7 SYSTEM DESCRIPTION
 - 1.7.1 Standard Operating Procedure
- 1.8 SYSTEM SUPPLIER INVOLVEMENT
- 1.9 DELIVERY, STORAGE, AND HANDLING
- 1.10 PROJECT/SITE CONDITIONS
 - 1.10.1 Field Measurements

PART 2 PRODUCTS

- 2.1 PERFORMANCE REQUIREMENTS
- 2.2 STANDARD COMMERCIAL PRODUCTS
- 2.3 MANUFACTURER'S STANDARD NAMEPLATES
- 2.4 PRE-CONDITIONED AIR UNIT
 - 2.4.1 Refrigerant and Oil
 - 2.4.2 Structural Base
 - 2.4.3 Receivers
 - 2.4.4 Compressors
 - 2.4.5 Motors and Drives
 - 2.4.6 Evaporator

- 2.4.7 Condenser
- 2.4.8 High Pressure Blower Assembly
- 2.4.9 Filters
- 2.4.10 Factory Applied Insulation
- 2.4.11 Condensate Removal
- 2.4.12 Operating Controls
 - 2.4.12.1 Unit Control Panel and Display
 - 2.4.12.2 Remote Controller
 - 2.4.12.3 Internal Sensors
 - 2.4.12.4 Adjustable Setpoints
 - 2.4.12.5 Monitoring Capabilities
 - 2.4.12.6 Safety Controls with Manual Reset
 - 2.4.12.7 Safety Controls with Automatic Reset
- 2.4.13 Factory Coating
- 2.4.14 Test Apparatus
- 2.4.15 Tools
- 2.5 ELECTRICAL WORK
 - 2.5.1 Controllers, Contactors, and Disconnects
 - 2.5.2 Electrical Control Wiring
- 2.6 SUPPLEMENTAL COMPONENTS
 - 2.6.1 Seismic Requirements
 - 2.6.2 Pre-Conditioned Air Piping
 - 2.6.3 Insulation
 - 2.6.3.1 Insulation Thickness Calculations
 - 2.6.4 Pre-Conditioned Air Flexible Duct, Storage and Accessories
- 2.7 FACTORY TESTS
 - 2.7.1 Manufacturer's Factory Test Plan
 - 2.7.1.1 Performance Variables
 - 2.7.1.2 Test Configuration
 - 2.7.1.3 Test Variables
 - 2.7.1.4 Specialized Components
 - 2.7.2 Production Schedule and Factory Test Schedule
 - 2.7.3 Factory Test
 - 2.7.4 Factory Test Report
 - 2.7.5 Deficiency Resolution

PART 3 EXECUTION

- 3.1 EXAMINATION
- 3.2 INSTALLATION
 - 3.2.1 Refrigeration System
 - 3.2.1.1 Equipment
 - 3.2.2 Field Painting
- 3.3 FIELD QUALITY CONTROL
 - 3.3.1 Manufacturer's System Certification
 - 3.3.2 Cleaning
 - 3.3.3 Preliminary Pneumatic Test
 - 3.3.4 Final Pneumatic Test
- 3.4 COMPONENT INSTALLATION
 - 3.4.1 Route Control Wiring
 - 3.4.2 Preconditioned Air Piping
- 3.5 ACCEPTANCE TESTS
 - 3.5.1 Pre-Conditioned Air System Performance Test Plan
 - 3.5.1.1 Functional Tests
 - 3.5.1.2 Endurance Test
 - 3.5.1.3 Instruments
 - 3.5.2 Notification of Pre-Conditioned Air System Performance Testing
 - 3.5.3 Performance Testing
 - 3.5.4 Performance Test Report

- 3.5.5 Deficiency Resolution and Re-testing
- 3.6 ADJUSTING AND CLEANING
- 3.7 CLOSEOUT ACTIVITIES
 - 3.7.1 Operation and Maintenance Manual
 - 3.7.2 Training Plan

-- End of Section Table of Contents --

Preparing Activity: NAVFAC

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2021

SECTION 23 75 15

CUSTOM-PACKAGED, AIRCRAFT PRE-CONDITIONED AIR UNITS 02/20

NOTE: This specification covers the requirements for high-pressure, preconditioned air units, ductwork and controls for aircraft cooling systems.

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

PART 1 GENERAL

1.1 SUMMARY

This specification covers the requirements for high-pressure, pre-conditioned air units, air distribution piping and controls for aircraft cooling systems.

1.2 RELATED SECTIONS

1.2.1 Electrical

Electrical installation must be in accordance with section [26 20 00](#) INTERIOR DISTRIBUTION SYSTEM.

1.2.2 Insulation

Section 23 07 00 THERMAL INSULATION FOR MECHANICAL SYSTEMS, applies to this section, with the additions and modifications specified herein.

1.2.3 Foam Fire Extinguishing System

Coordinate PCA system installation with requirements of Section 21 13 20.00 20 FOAM FIRE EXTINGUISHING FOR AIRCRAFT HANGARS. Ensure all ducts subject to foam or water infiltration are sealed and insulation and waterproof jacket installation is complete prior to testing foam fire extinguishing system.

1.2.4 Field Painting

Painting required for surfaces not otherwise specified, and finish painting of items only primed at the factory is specified in Section 09 90 00 PAINTS AND COATINGS.

1.3 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AIR-CONDITIONING, HEATING AND REFRIGERATION INSTITUTE (AHRI)

AHRI 410 (2001; Addendum 1 2002; Addendum 2 2005; Addendum 3 2011) Forced-Circulation Air-Cooling and Air-Heating Coils

AMERICAN BEARING MANUFACTURERS ASSOCIATION (ABMA)

ABMA 9 (2015) Load Ratings and Fatigue Life for Ball Bearings

ABMA 11 (2014) Load Ratings and Fatigue Life for Roller Bearings

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING
ENGINEERS (ASHRAE)

ANSI/ASHRAE 15 & 34 (2013) ANSI/ASHRAE Standard 15-Safety
Standard for Refrigeration Systems and
ANSI/ASHRAE Standard 34-Designation and
Safety Classification of Refrigerants

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

ASME A13.1 (2020) Scheme for the Identification of
Piping Systems

ASME B16.25 (2017) Buttwelding Ends

ASME B31.3 (2020) Process Piping

ASME B31.5 (2020) Refrigeration Piping and Heat
Transfer Components

ASME BPVC SEC VIII D1 (2019) BPVC Section VIII-Rules for
Construction of Pressure Vessels Division 1

ASTM INTERNATIONAL (ASTM)

ASTM A312/A312M (2021) Standard Specification for
Seamless, Welded, and Heavily Cold Worked
Austenitic Stainless Steel Pipes

ASTM B117 (2019) Standard Practice for Operating
Salt Spray (Fog) Apparatus

ASTM C578 (2019) Standard Specification for Rigid,
Cellular Polystyrene Thermal Insulation

ASTM E84 (2020) Standard Test Method for Surface
Burning Characteristics of Building
Materials

ASTM F593 (2017) Standard Specification for
Stainless Steel Bolts, Hex Cap Screws, and
Studs

ASTM F594 (2009; R 2020) Standard Specification for
Stainless Steel Nuts

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION (ISO)

ISO 281 (2007) Rolling Bearings -- Dynamic Load
Ratings and Rating Life

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA MG 1 (2018) Motors and Generators

NEMA MG 2 (2014) Safety Standard for Construction
and Guide for Selection, Installation and
Use of Electric Motors and Generators

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2020; ERTA 20-1 2020; ERTA 20-2 2020; TIA 20-1; TIA 20-2; TIA 20-3; TIA 20-4)
National Electrical Code

SOCIETY OF AUTOMOTIVE ENGINEERS INTERNATIONAL (SAE)

SAE ARP5374 (2001; R 2016) Method of Testing
Pre-Conditioned Air Equipment

SAE AS38386 (1999; R2013) Duct Assembly, Ground,
Conditioned Air, Insulated, Flexible

U.S. DEPARTMENT OF DEFENSE (DOD)

UFC 3-301-01 (2019) Structural Engineering

UNDERWRITERS LABORATORIES (UL)

UL 508 (2018; Reprint Jul 2021) UL Standard for
Safety Industrial Control Equipment

UL 1995 (2015) UL Standard for Safety Heating and
Cooling Equipment

1.4 SEQUENCING

Submit drawings showing foundation bolt locations, trench sizes, and access hatch points as required by paragraph PRE-CONDITIONED AIR SYSTEM DETAIL DRAWINGS prior to concrete foundation construction.

Coordinate pre-conditioned air distribution piping work with testing of Section 21 13 20.00 20 FOAM FIRE EXTINGUISHING FOR AIRCRAFT HANGARS. Ensure all ducts subject to foam or water infiltration are sealed and insulation and waterproof jacket installation is complete prior to testing foam fire extinguishing system.

As a prerequisite to government witnessed acceptance testing, the Contractor must submit a Certificate of Completion that certifies all PCA System work and quality control documentation has been completed.

1.5 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

Choose the first bracketed item for Navy, Air Force, and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are [for Contractor Quality Control approval.][for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

System Supplier's Qualifications; G[, [____]]

Manufacturer's Factory Test Plan; G[, [____]]

Pre-Conditioned Air System Performance Test Plan; G[, [____]]

SD-02 Shop Drawings

Pre-Conditioned Air System Detail Drawings; G[, [____]]

SD-03 Product Data

Pre-Conditioned Air Unit; G[, [____]]

Pre-Conditioned Air Piping; G[, [____]]

Insulation; G[, [____]]

Pre-Conditioned Air Flexible Duct, Storage And Accessories; G[, [____]]

SD-05 Design Data

Insulation Thickness Calculations; G[, [____]]

SD-06 Test Reports

Final Pneumatic Test; G[, [____]]

Performance Test Report; G[, [____]]

SD-07 Certificates

Factory Test Report; G[, [____]]

Manufacturer's System Certification; G[, [____]]

Certificate of Completion; G[, [____]]

Notification of Pre-Conditioned Air System Performance Testing; G
[, [____]]

SD-08 Manufacturer's Instructions

Installation Manual; G[, [____]]

SD-11 Closeout Submittals

Operation and Maintenance Manual

Training Plan

Safety Data Sheets

1.6 QUALITY CONTROL

1.6.1 System Supplier's Qualifications

PCA system supplier must have at least three previous successful PCA system installations in the last five years. Submit a letter listing prior projects, the date of construction, a point of contact for each prior project, the scope of work of each prior project, and a detailed list of work performed. The system supplier must supervise the installing, adjusting and testing of the equipment.

1.6.2 Pre-Conditioned Air System Detail Drawings

NOTE: Size PCA units for the greatest enthalpy condition when comparing the 0.4 percent dry-bulb and mean coincident wet-bulb (DB/MCWB) and the 0.4 percent humidity ratio and mean coincident dry-bulb (HR/MCDB) design conditions using weather data prescribed by UFC 3-400-02.

The greatest enthalpy condition usually occurs at the 0.4 percent HR/MCDB condition. Include PCA pipe and flexible duct heat losses in PCA unit sizing. Use a safety factor of 10 percent when sizing PCA equipment.

Select minimum continuous operation capacity and heating components based on the 99.6 percent winter design dry bulb for the location using weather data prescribed by UFC 3-400-02.

In cold climates, a heater may be required to deliver the minimum aircraft delivery temperature. In high altitude locations, ensure air density corrections factors are provided for PCA unit and test bullet mass airflow calculations.

Submit design calculations and detail drawings stamped by a licensed professional engineer showing equipment layout, including assembly and installation details and electrical connection diagrams; piping layout showing the location of all supports and hangers, typical hanger details, gauge reinforcement, reinforcement spacing rigidity classification, and pressure testing locations. Show equipment relationship to other parts of the work, including clearances required for operation and maintenance. Submit drawings showing foundation bolt locations, trench sizes, and access hatch points prior to concrete foundation construction. Submit product data of the equipment, materials and all accessories specified throughout this Section required to deliver a fully functional system. Provide control system drawings which include point-to-point electrical wiring diagrams. Include any information required to demonstrate that the system has been coordinated and functions properly. Include step-by-step operating procedures with detail drawings.

Provide calculations demonstrating the equipment meets the performance requirements at the design condition [of [____] **grams per kilogram grains per pound** humidity and [____] **degrees C degrees F** dry-bulb][as scheduled]. Provide calculations demonstrating that equipment meets the performance requirements at the winter design condition [of [____] **degrees C degrees F**] [as scheduled]. Provide unit capable of continuous stable operation under a minimum load of [10 percent] [____] of the rated capacity. If minimum operating temperature is less than the minimum aircraft delivery temperature, provide PCA unit with heating capability and sizing calculations. Include fan heat gain in the calculation of heater size. Provide schedule of equipment supplied. Schedule must provide a cross reference between manufacturer data and identifiers indicated in shop drawings. Schedule must include the total quantity of each item of equipment supplied. Provide recommended spare parts listing for each assembly or component.

1.6.3 Certificate of Completion

As a prerequisite to government witnessed acceptance testing, the Contractor must submit a Certificate of Completion that certifies all PCA System work and quality control documentation has been completed. Certificate of Completion must include all quality control documentation including preliminary test reports, pneumatic test reports weld inspection reports and NDE testing reports required by **23 64 26** CHILLED, CHILLED-HOT, AND CONDENSER WATER PIPING SYSTEMS.

Further, the Contractor Quality Control Manager must certify that all required checks, inspections, and preliminary tests have been successfully completed. The Contractor must provide the Contracting Officer at least [45][30] calendar days' notice prior to commencement of acceptance testing.

1.7 SYSTEM DESCRIPTION

Provide aircraft preconditioned air system having the performance requirements indicated. Provision of the equipment, piping, controls, insulation, flexible duct, reel, and other appurtenances, including

materials, installation, workmanship, fabrication, assembly, erection, examination, inspection, and testing must be in accordance with this specification section, design drawings and referenced requirements.

1.7.1 Standard Operating Procedure

NOTE: Do not modify the SOP.

The control points, components, and capabilities specified herein will support the PCA system standard operating procedures (SOP) as follows.

1. Remove dust cap from PCA piping.
2. Start PCA purge mode.
3. Prepare to connect flex duct to aircraft. If present, open manual blow-down valve(s) to purge any trapped condensation.
4. When desired temperature is reached as indicated at temperature gauge, and there is no visible moisture in the duct, stop PCA purge mode.
5. Connect flexible duct to the PCA duct and aircraft, then start PCA normal mode.
6. Stop PCA unit, disconnect flexible duct, and replace dust cap.

1.8 SYSTEM SUPPLIER INVOLVEMENT

The Contractor and the System Supplier must work together to prepare the work plan, commissioning plan, test reports and final reports. They must both be present during all field testing activities and must coordinate and schedule the work during construction, testing, calibration and acceptance of the system, and operator training. The System Supplier must be responsible to the Contractor for scheduling all Contractor, Sub-Contractor, and manufacturer's service personnel during system startup, commissioning, and acceptance.

1.9 DELIVERY, STORAGE, AND HANDLING

Stored equipment and materials must be protected from the weather, humidity and temperature variations, dirt and dust, or other contaminants. Proper protection and care of all material both before and during installation is the Contractor's responsibility. Any materials found to be damaged must be replaced at the Contractor's expense. During installation, piping and similar openings must be capped to keep out dirt and other foreign matter.

1.10 PROJECT/SITE CONDITIONS

1.10.1 Field Measurements

After becoming familiar with all details of the work, verify all dimensions in the field, and advise the Contracting Officer of any discrepancy before performing the work.

PART 2 PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

NOTE: Obtain performance requirements from aircraft manufacturer. F-35 cooling air performance requirements are found in the Joint Strike Fighter Facilities Requirement Document (FRD).

Unit Performance Criteria Measured at Point of Aircraft Connection	
Air Temperature	[] degrees C F Minimum [] degrees C F Maximum
Mass Flow Rate	[] kg/min lb/min (ppm) Minimum
Air Pressure	[] kPa psig Minimum [] kPa psig Maximum
Moisture Content of Dry Air	[] kg/kg dry air grains/lb dry air Maximum

2.2 STANDARD COMMERCIAL PRODUCTS

Use a product from a manufacturer who is regularly engaged in the design, fabrication, testing, and service of pre-conditioned air units of type and size required for this project. Materials and equipment will be standard commercial cataloged products. These products must have a two year record of satisfactory field service prior to proposal due date. The two year record of service must include applications of equipment and materials under similar circumstances and of similar size.

2.3 MANUFACTURER'S STANDARD NAMEPLATES

Nameplates are required on major components if the manufacturer needs to provide specific engineering and manufacturing information pertaining to the particular component. Should replacement of this component be required, nameplate information will insure correct operation of the unit after replacement of this component.

2.4 PRE-CONDITIONED AIR UNIT

NOTE: For units located near sound sensitive spaces, use noise criteria in brackets. Designer of record must determine the allowable sound power noise level and select equipment location to ensure interior noise requirements are met.

Provide high pressure, packaged pre-conditioned air unit designed for 100 percent fresh air. Unit must be assembled, leak-tested, charged (refrigerant and oil), and adjusted at the factory. Unit must operate within capacity range and speed recommended by the manufacturer based on the maximum outdoor enthalpy condition as shown. Unit must be fully UL listed under **UL 1995**. Certification must be submitted with product data.

Unit must be designed to minimize noise and vibration to adjacent buildings.[Unit must operate at all conditions with a measured sound power noise level less than [85][____] dBA.]

Parts weighing 50 pounds or more which must be removed for inspection, cleaning, or repair, must have lifting eyes or lugs. Include customary auxiliaries for each unit as deemed necessary by the manufacturer for safe, controlled, automatic operation of equipment. Provide unit with single point wiring connection for incoming power supply. Access doors or panels suitably sized and located must be provided for access to filters, coils, valves, and any other items requiring cleaning, repair, or removal. Access doors or panels must be gasketed with synthetic rubber, or equivalent gasket material, and locked in place with thumb screws or catches.

2.4.1 Refrigerant and Oil

**NOTE: Pre-conditioned air units must operate on a
refrigerant with an ODP equal to 0. R-134a, R-407C,
and R-410A all meet this requirement.**

Provide factory refrigerant charge and oil. Refrigerants must be one of the fluorocarbon gases. Refrigerants must have number designations and safety classifications in accordance with ANSI/ASHRAE 15 & 34. CFC-based refrigerants are prohibited. Refrigerants must have an Ozone Depletion Potential (ODP) no greater than 0.0. Provide safety data sheets for all refrigerants.

2.4.2 Structural Base

Provide a structural steel base (welded or bolted) or support legs with factory finish specified in paragraph FACTORY COATING. Unit and individual components must be isolated from the building structure by means of vibration isolators with published load ratings. Vibration isolators must have isolation characteristics as recommended by the manufacturer for the unit supplied and the service intended.

2.4.3 Receivers

Receivers, if required, must bear a stamp certifying compliance with ASME BPVC SEC VIII D1 and must meet the requirements of ANSI/ASHRAE 15 & 34. Inner surfaces must be thoroughly cleaned by sandblasting or other approved means. Each receiver must have a storage capacity not less than 20 percent in excess of that required for the fully-charged system. Each receiver must be equipped with isolation valve and relief valves of capacity and setting required by ANSI/ASHRAE 15 & 34, and two bull's eye liquid-level sight glasses. Provide sight glass in receiver liquid line.

2.4.4 Compressors

Compressors must be of the hermetically sealed design. Compressors must be mounted on vibration isolators to minimize vibration and noise. Rotating parts must be statically and dynamically balanced at the factory to minimize vibration. Lubrication system must be centrifugal pump type equipped with a means for determining oil level and an oil charging valve. Crankcase oil heater must be provided for cold climates. Provide compressor capable of unloading to 10 percent of rated capacity.

2.4.5 Motors and Drives

- a. Electric motors and motor efficiencies must be in accordance with Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM. When motors and equipment furnished are larger than sizes indicated, the cost of providing additional electrical service and related work must be included under this section. Provide variable-speed motors with variable frequency drive as required by the manufacturer and as specified in Section 26 29 23 VARIABLE FREQUENCY DRIVE SYSTEMS UNDER 600 VOLTS. Drives speed controls must be programmed to prevent blower and condenser fans from operating in the region of instability on the fan airflow-pressure curve.
- b. Electrical motor driven equipment specified must be provided complete with motors, motor starters, and controls. Unless otherwise indicated, all motors of one horsepower and above with totally enclosed, or explosion proof fan cooled enclosures, must be the premium efficiency type in accordance with NEMA MG 1. Each motor must conform to NEMA MG 1 and NEMA MG 2 and be of sufficient size to drive the equipment at the specified capacity without exceeding the nameplate rating of the motor.
- c. Motors must be continuous duty with the enclosure specified. Provide motor starters complete with thermal overload protection and other appurtenances necessary for the motor control indicated. Motor duty requirements must allow for maximum frequency start-stop operation and minimum encountered interval between start and stop. Motors must be sized for the applicable loads. Provide inverter duty premium efficiency motors for use with variable frequency drives.
- d. Motor torque must be capable of accelerating the connected load within 20 seconds with 80 percent of the rated voltage maintained at motor terminals during one starting period. Motor bearings must be fitted with grease supply fittings and grease relief to outside of enclosure where applicable. Manual or automatic control and protective or signal devices required for the operation specified and any control wiring required for controls and devices specified, but not shown, must be provided. Motor enclosure type must be either TEAO or TEFC.

2.4.6 Evaporator

NOTE: Standard coil construction is copper tubes with aluminum fins. For excessively corrosive atmospheres, either copper tubes with copper fins or copper tubes with pre-plated aluminum fins.

Provide AHRI 410 coils constructed of seamless copper tubes with compatible [aluminum] [pre-plated aluminum] fins. Fins must be soldered or mechanically bonded to the tubes and installed in a stainless steel or aluminum casing. Evaporator air velocity must be sufficiently low to prevent moisture carryover into the air distribution piping.

2.4.7 Condenser

NOTE: Standard coil construction is copper tubes

with aluminum fins. For excessively corrosive atmospheres, either copper tubes with copper fins or copper tubes with pre-plated aluminum fins.

Condenser coil must be of the extended-surface fin-and-tube type and must be constructed of seamless copper tubes with compatible [aluminum] [pre-plated aluminum] fins. Fins must be soldered or mechanically bonded to the tubes. Coils must be circuited and sized for a minimum of 5 degrees F subcooling and full pump down capacity.

Coil must be factory leak and pressure tested after assembly in accordance with ANSI/ASHRAE 15 & 34. Provide coils constructed of aluminum alloys for fins, tubes, and manifolds. Coil must be factory leak and pressure tested after assembly in accordance with ANSI/ASHRAE 15 & 34.

2.4.8 High Pressure Blower Assembly

High pressure centrifugal blower, permanently-lubricated high-speed bearings. Integral cooling system for blower assembly. Bearing housing must be conservatively loaded and rated for an L(10) life of not less than 200,000 hours per ISO 281. Precision main bearings with heavy duty bushings in accordance with ABMA 9 or ABMA 11. Shaft seal suitable for high pressure applications.

2.4.9 Filters

Provide washable pre-filter and final filter installed at the inlet of the blower and accessible for maintenance through an access opening. Pre-filter must be constructed of washable mesh media that traps dust, foreign matter, and contaminants and is easily cleaned by flushing with water. Final filter efficiency must be high-efficiency, minimum MERV-8 and approved by manufacturer.

2.4.10 Factory Applied Insulation

PCA equipment must be provided with factory installed insulation on surfaces subject to condensation including the evaporator enclosure, suction line piping, economizer, and cooling lines. Factory insulated items installed outdoors are not required to be fire-rated.

2.4.11 Condensate Removal

Provide a means for condensate removal including an automatic drain valve, stainless steel drain line, stainless steel condensate pan and condensate sensor. Condensate drain valve must open intermittently, as needed, to prevent continuous air leakage from evaporator housing. Include a high condensate level alarm and safety shut down. Insulate condensate drain piping per Section 23 07 00 THERMAL INSULATION FOR MECHANICAL SYSTEMS.

2.4.12 Operating Controls

Provide units complete with factory installed, UL 508-listed microprocessor based operating and safety control system. Controls must process the signals for complete control and monitoring of pre-conditioned air cooling units. Provide safety alarms with automatic shutoff. Provide proportional-integral controls to regulate system capacity and fan speed control to satisfy adjustable set points. Provide a defrost cycle to prevent coil freezing. Defrost cycles will allow discharge temperature

from individual units to increase to 35-55 degrees F for up to 90 seconds every 15 minutes.

Provide a dedicated, low-pressure purge mode to allow cool-down of the duct. Purge mode set points including temperature, pressure, and mass flow rate, and automatic shutoff timer (5-30 minutes) must be independently adjustable at the unit control panel.

2.4.12.1 Unit Control Panel and Display

Provide a unit-mounted, touch-screen display to allow adjustment of set points including temperature, pressure, and mass flow rate. Display must show sensor data, set points, operating status of components, monitored points, and alarms. Each safety interlock requiring a manual reset must be displayed at the top-level screen without requiring a password. Non-recycling control interlocks must have the reset located on the control itself that will identify the lockout information required below. Controls must illuminate the fault indicator at the unit and remote controller upon a power failure.

2.4.12.2 Remote Controller

Provide a remote controller along the hangar back wall for each PCA unit with step-by-step operating procedures posted on the controller cover. The remote controller must be one panel provided by equipment manufacturer. Remote controller must perform the following functions:

- a. Blue purge mode start button.
- b. Green aircraft cooling mode start button.
- c. Red stop button.
- d. White unit run status light.
- e. Red illuminated fault light.
- f. Digital display of PCA unit discharge temperature, humidity, pressure, and mass flow rate.

2.4.12.3 Internal Sensors

The following sensors must be provided internal to the unit. All sensors must have accuracy as indicated.

- a. Discharge temperature sensor, minus 17.8 to 65.6 degrees C 0 to 150 degrees F, accurate to plus or minus 0.3 degrees C 0.5 degrees F.
- b. Ambient temperature sensor, minus 17.8 to 65.6 degrees C 0 to 150 degrees F, accurate to plus or minus 0.3 degrees C 0.5 degrees F.
- c. Discharge pressure sensor, minus 103 to 345 kPa minus 15 to 50 psig, accurate to plus or minus 0.5-percent.
- d. Discharge humidity sensor, 0 to 100 percent relative humidity (RH), accurate to plus or minus 5 percent RH.
- e. Air velocity measurement sensor, 0 to 20.3 m/s 0 to 4,000 fpm, accurate to plus or minus 5 percent over a temperature range of minus

28.9 to 101.1 degrees C minus 20 to 150 degrees F.

- f. Mass air flow sensor, 0 to 45.4 kg/min 0 to 100 lb/min, accurate to plus or minus 5 percent over a temperature range of minus 28.9 to 101.1 degrees C minus 20 to 150 degrees F.

2.4.12.4 Adjustable Setpoints

The following points must be capable of being adjusted directly at the unit. A security access code must be entered before parameters can be changed.

- a. Leaving air temperature control.
- b. Leaving air pressure control.
- c. Mass air flow rate.

2.4.12.5 Monitoring Capabilities

During normal operations, the control system must be capable of monitoring and displaying the following operating parameters on the operator interface terminal at the unit. The display must be accessible without opening or removing any panels or doors.

- a. Leaving air temperatures.
- b. Leaving air pressure.
- c. Leaving air mass flow rate.
- d. Leaving air humidity.
- e. Self-diagnostic.
- f. Operation status.
- g. Operating hours.
- h. Number of starts.
- i. Compressor status (on or off).
- j. Compressor speed.
- k. Condenser fan status.
- l. Refrigerant discharge and suction pressures.

2.4.12.6 Safety Controls with Manual Reset

Pre-conditioned air cooling unit must be provided with the following safety controls which automatically shut down the pre-conditioned air cooling unit, display an alarm at unit and remote controller, and which require manual reset.

- a. Low airflow detection.
- b. High discharge air pressure.

- c. High refrigerant pressure.
- d. High motor winding temperature protection.
- e. Motor current overload and phase loss protection.
- f. High condensate level.

2.4.12.7 Safety Controls with Automatic Reset

Pre-conditioned air cooling unit must be provided with the following safety controls with automatic reset, and alarm.

- a. Low refrigerant pressure safety shutdown.
- b. Over/under voltage protection.
- c. Phase reversal protection.
- d. Short cycle protection.
- e. Load limiting to prevent over-pressurization.

2.4.13 Factory Coating

Equipment casing and structural base, when fabricated from ferrous metal, must be factory coated with a coating rated for 3,000 hours' exposure to the salt spray test specified in [ASTM B117](#) using a 5 percent sodium chloride solution.

2.4.14 Test Apparatus

One testing spool piece, or test bullet, must be provided to support field testing. Test bullet must be provided with calibrated gauges to measure all cooling air performance parameters including, but not limited to, temperature, flow, pressure, and humidity. Provide lab testing for air particulates if required by the contracting officer. Provide test bullet with calibrated orifice plate to simulate aircraft back pressure. Provide test bullet complete with carrying case, and turn over to the contracting officer upon contracting officer acceptance of the PCA system.

2.4.15 Tools

One complete set of special tools, if required for access to PCA equipment panels and routine maintenance, must be provided. Tools must be [provided to the maintenance activity][provided with a weatherproof toolbox attached to the unit structure].

2.5 ELECTRICAL WORK

2.5.1 Controllers, Contactors, and Disconnects

Furnish with respective pieces of equipment. Electrical equipment, controllers, contactors and disconnects must conform to Section [26 20 00 INTERIOR DISTRIBUTION SYSTEM](#), as modified and supplemented by this section. Provide electrical connections under Section [26 20 00 INTERIOR DISTRIBUTION SYSTEM](#). Provide controllers and contactors with maximum of 120 volt control circuits, and auxiliary contacts for use with controls

furnished.

2.5.2 Electrical Control Wiring

NOTE: Choose the control specification applicable to the basis of design. Use Section 23 09 00 INSTRUMENTATION AND CONTROL FOR HVAC for low voltage remote control panels and use Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM for line voltage control panels.

[Provide control wiring under Section 23 09 00 INSTRUMENTATION AND CONTROL FOR HVAC.] [Provide control wiring under this section in accordance with NFPA 70 and Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM.] Field wiring must be in accordance with manufacturer's instructions.

2.6 SUPPLEMENTAL COMPONENTS

2.6.1 Seismic Requirements

NOTE: Provide seismic details on the drawings, if performed by the DoR. Delete the bracketed phrase "as shown on the drawings" if no seismic details are provided.

If seismic design is delegated, specify seismic bracing of PCA piping and equipment in accordance with applicable codes and standards. UFC 3-301-01, "Structural Engineering" and SECTIONS 13 48 73 SEISMIC CONTROL FOR MECHANICAL EQUIPMENT and 23 05 48.19 [SEISMIC] BRACING FOR HVAC or 22 05 48.00 20 MECHANICAL SOUND, VIBRATION, AND SEISMIC CONTROL properly edited, must be included in the contract documents.

Piping and equipment must be supported and braced to resist seismic loads as specified under UFC 3-301-01 and Sections 13 48 73 SEISMIC CONTROL FOR MECHANICAL EQUIPMENT and [23 05 48.19 [SEISMIC] BRACING FOR HVAC] [22 05 48.00 20 MECHANICAL SOUND, VIBRATION, AND SEISMIC CONTROL] [as shown on the drawings]. Structural steel required for reinforcement to properly support piping, headers, and equipment but not shown must be provided under this section. Material used for support must be as specified under Section 05 12 00 STRUCTURAL STEEL.

2.6.2 Pre-Conditioned Air Piping

NOTE: Choose pressure rating of 150 percent of maximum operating pressure of the equipment specified.

Provide fully welded air distribution piping of schedule [5][10], type 304L stainless steel conforming to ASTM A312/A312M and suitable for a working pressure of [15][_____] psig. Stainless fittings and joints must

be butt-welded in accordance with ASME B16.25. Piping must be supported by the hangar structure or utility trench. Piping design including supports must account for and control thermal expansion. Provide ASME A13.1 compliant piping labels every 20 feet and at each change in direction indicating direction of flow and associated PCA unit equipment designation. Provide flanged piping within 18 inches of the hangar floor and in utility trenches in the hangar. Provide non-absorptive neoprene or rubber gaskets at all flanges. Provide stainless steel nuts, bolts, and washers for all flanges in accordance with ASTM F593 and ASTM F594.

Do not install valves downstream of the pre-conditioned air unit. Provide duct-mounted, mechanical temperature and pressure gauges at the PCA duct connection point. Provide a water tight, soft rubber cover with lanyard to protect the PCA duct opening while not in use. End cap must connect to piping with the use of hand-operated quick-connect connectors.

2.6.3 Insulation

Insulate pre-conditioned air system piping with factory applied polyisocyanurate insulation and jacket covers meeting ASTM C578. Insulation must meet the flame spread index of 25 and the smoke developed index of 50 when tested in accordance with ASTM E84. Provide a water-tight embossed aluminum or high density polyurethane (HDPE) jacket for all insulation. Installation must conform to requirements of Section 23 07 00 THERMAL INSULATION FOR MECHANICAL SYSTEMS.

2.6.3.1 Insulation Thickness Calculations

NOTE: Designers must increase insulation in high humidity areas to prevent condensation. For example, the outdoor air dew point for Guam is 27.3 degrees C 81.2 degrees F at the 0.4 percent humidity ratio condition.

Perform heat loss calculations based on insulation thickness and equipment performance requirements to demonstrate that insulation is sufficient to deliver the prescribed conditions in section titled PERFORMANCE REQUIREMENTS at the aircraft and to prevent condensation based on outdoor dew point at 0.4 percent humidity ratio condition. Actual insulation values and maximum PCA piping length for the project must be used in calculations.

2.6.4 Pre-Conditioned Air Flexible Duct, Storage and Accessories

NOTE: Specify flexible duct length based on the maximum distance between aircraft parking positions and duct connection points.

Provide [35][____]-foot flexible duct, [6][____]-inch diameter, conforming to SAE AS38386 with hand-operated quick-connect connectors for connection between the PCA piping termination and the aircraft. Flexible duct must be fully insulated with a metal helical stiffener core to prevent collapse and suitable for an operating pressure of 150 percent of the aircraft delivery pressure. Provide manufacturer's certification that the air temperature rise in the flexible duct is less than 0.2 degree F

per foot when tested at the maximum outdoor ambient design temperature and median aircraft delivery temperature and pressure conditions.

Provide a hard 45-degree transition attached to the inlet of the flexible duct. Provide all necessary transitions with insulating sleeve. Obtain list of approved aircraft connectors from aircraft program Facilities Requirements Document (FRD). Provide insulated flexible duct with a mobile basket or reel to connect from the PCA pipe connection to the aircraft PCA connection. Equip flexible duct storage basket or reel with heavy-duty casters and integral storage for transitions.

2.7 FACTORY TESTS

2.7.1 Manufacturer's Factory Test Plan

Perform factory test on PCA equipment prior to delivery to validate the specified full load capacity. Testing must be performed at the factory in accordance with [SAE ARP5374](#) by manufacturer. At a minimum, PCA equipment capacity must be validated to meet the scheduled requirements as indicated. Factory testing to be performed in a controlled environment lab that is capable of simulating extreme ambient conditions witnessed by the installation location. PCA unit must also be tested under minimum load conditions. Stable operation at minimum load of 10 percent of total capacity must be demonstrated during the factory test. Test reports to include ambient conditions and results from each test.

For each unit, submit a factory test plan which verifies the scheduled performance is met by the produced units. Indicate in each test plan the factory acceptance test procedures. Include a detailed step-by-step procedure to test all modes of operation to confirm that the controls through all modes of control to confirm that the controls are performing in accordance with the intended sequence of control. Perform calibration of controllers and sensors, ensure set points are programmed, and control variables are tuned to provide stable control of their respective equipment. Include the required test reporting forms to be completed by the Manufacturer's testing representatives. Submit the required test plans for review and approval to the Contracting Officer at least 90 calendar days before scheduled factory test date.

2.7.1.1 Performance Variables

List performance variables that are required to be measured or tested as part of the factory test plan. Include the actual performance variables during testing as well as the performance requirements indicated on equipment schedules on the contract design drawings on each test form. Provide a description of acceptable performance results and objective quality evidence which will verify performance results. Identify the limits or tolerances within which each tested performance variable is deemed to be acceptable.

2.7.1.2 Test Configuration

Tests must be performed for a minimum of four continuous hours in a wet coil condition. If test period is interrupted, restart the four-hour test period. Each test plan must be job specific and address the particular units and particular conditions which exist with this contract. Generic or general preprinted test procedures are not acceptable.

2.7.1.3 Test Variables

Air side testing variables must include recording of the airflow, total static pressure; fan drive motor KW, amperage and RPM; and fan RPM. Perform test with entering air at scheduled design conditions.

2.7.1.4 Specialized Components

Include procedures for field testing and field adjusting specialized components, such as hot gas bypass control valves, or pressure valves.

2.7.2 Production Schedule and Factory Test Schedule

The Government reserves the right to witness factory tests for pre-conditioned air cooling units. Provide the production schedule and factory test schedule for tests to be performed at the manufacturer's test facility. Submit planned production schedule, and factory test schedule and test location, to the Contracting Officer as soon as it is scheduled but not less than 90 calendar days prior to the scheduled factory test date. Track this schedule through the production phases and if scheduled factory tests date changes, give advanced notice to Contracting Officer as soon as possible, but at least 30 calendar days in advance of the scheduled test dates.

2.7.3 Factory Test

Conduct the factory testing in compliance with the Contracting Officer approved Manufacturer's Factory Test Plan, and in accordance with additional field testing requirements specified herein. Conduct the test for each unit for the continuous test period in the approved test plan. If a unit shuts down before the continuous test period is completed, the test procedure must be restarted and run for the required duration.

2.7.4 [Factory Test Report](#)

Record the required data using the test reporting forms of the approved test plan. Final test report forms must be typed including data entries and remarks. Completed test report forms for each unit must be reviewed, approved, and signed by the Manufacturer's test director. Submit factory test reports, referencing each tested unit's serial number, and receive approval before delivery of unit to the project site.

2.7.5 Deficiency Resolution

Deficiencies identified during the tests must be corrected in compliance with the manufacturer's recommendations and corrections tested as specified in the paragraph titled FACTORY TEST.

PART 3 EXECUTION

3.1 EXAMINATION

After becoming familiar with all details of the work, perform verification of dimensions in the field, and advise the Contracting Officer of any discrepancy before performing any work.

3.2 INSTALLATION

Provide manufacturer's [installation manual](#) for each type of unit. Perform

all work in accordance with the manufacturer's published diagrams, recommendations, and equipment warranty requirements.

Piping installation must conform to ASME B31.3. Welding, vents, drains, hangers, inserts, penetrations, and supports must conform to the requirements of Section 23 64 26 CHILLED, CHILLED-HOT AND CONDENSER WATER PIPING AND ACCESSORIES paragraph titled "INSTALLATION".

3.2.1 Refrigeration System

3.2.1.1 Equipment

Refrigeration equipment and the installation thereof must conform to ANSI/ASHRAE 15 & 34 and ASME B31.5. Provide necessary supports for all equipment, appurtenances, and pipe as required, including frames or supports for compressors, condensers, and similar items. Select and size isolators based on load-bearing requirements and the lowest frequency of vibration to be isolated. Equipment must be properly leveled, aligned, and secured in place in accordance with manufacturer's instructions.

3.2.2 Field Painting

Painting required for surfaces not otherwise specified, and finish painting of items only primed at the factory is specified in Section 09 90 00 PAINTS AND COATINGS.

3.3 FIELD QUALITY CONTROL

3.3.1 Manufacturer's System Certification

Upon completion and before final acceptance testing of work, a factory-trained representative must verify on-site the PCA equipment installation compliance with manufacturer's recommendations. Manufacturer's representative must check each unit under pressure for refrigerant leaks. If leaks are found, evacuate and dehydrate the machine to an absolute pressure of 300 microns prior to repair and recharge. Verify and record proper refrigeration charge.

Manufacturer's representative must test controls through every cycle of operation, verify safeties, make necessary adjustments, and balance systems prior to scheduling acceptance testing of completed systems. Controllers must be verified to be properly calibrated and have the proper set point to provide stable control of their respective equipment. Submit manufacturer's system certification at least 30 calendar days in advance of the scheduled acceptance test date.

3.3.2 Cleaning

Clean piping before placing in operation. Clean equipment, piping, filters, and accessories. Prior to commencement of field testing, remove all filters and provide new filters.

3.3.3 Preliminary Pneumatic Test

Prior to insulating PCA piping joints, apply a 15 psig pneumatic test to PCA piping, not including flexible duct and connector. Maintain the pressure while soapsuds or equivalent materials are applied to the exterior of the piping. While applying the soapsuds, visually inspect the entire run of piping, including the bottom surfaces, for leaks (bubble

formations). If leaks are discovered, repair the leaks accordingly and retest

3.3.4 Final Pneumatic Test

Prior to insulating PCA piping joints, tightness test PCA piping, not including flexible duct and connector, with air at a pressure of 15 psig. Pressurize the system and isolate the source of pressure. No leakage is permitted at the end of one hour as indicated by a drop in system pressure. Test must be witnessed by government personnel, and a final pneumatic test report submitted for approval by the quality control manager (QCM). If any test section fails tightness testing, repair or replace all defective materials and/or workmanship.

3.4 COMPONENT INSTALLATION

3.4.1 Route Control Wiring

Route control wiring in rigid conduit per Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM.

3.4.2 Preconditioned Air Piping

Support all above ground piping including piping located in trench per Section 23 64 26 CHILLED, CHILLED-HOT, AND CONDENSER WATER PIPING SYSTEMS. Provide insulation shields at supports and provide a water-tight embossed aluminum or HDPE jacket over entire service.

3.5 ACCEPTANCE TESTS

Pre-conditioned air system final acceptance tests will be witnessed by the Contracting Officer and other Government representatives. Furnish a factory trained field test director authorized by the PCA equipment manufacturer to oversee the complete execution of the field testing. This test representative must also review, approve, and sign the completed Performance Test Report. Signatures must be accompanied by the person's name.

3.5.1 Pre-Conditioned Air System Performance Test Plan

Submit a performance test plan for each PCA system at least 90 calendar days in advance of the scheduled acceptance test date for Contracting Officer approval. Submit the performance test plan along with the completed factory test plan specified herein. Include field test director's qualifications and factory training certification.

3.5.1.1 Functional Tests

Test plan must include detailed step-by-step procedures to verify the functional performance of the complete PCA system including all modes of operation and safety controls. Each test step must include the procedure used to simulate conditions, the expected responses, and space for comments. Test plan must include list of participants and equipment needed to perform the test. Describe test set-up to simulate real-world operation of the entire system including flexible duct.

3.5.1.2 Endurance Test

In addition to functional tests, test plan must include an endurance test

to verify system performance when the ambient outdoor conditions are within 10percent of the design maximum enthalpy condition. Include a form to record performance variables at 15-minute intervals during the test. Performance variables must be measured at aircraft connection point under the same test set-up as the functional tests.

- a. Pre-conditioned air unit discharge temperature (degrees C F)
- b. Aircraft connection temperature (degrees C F)
- c. Pre-conditioned air unit discharge pressure (kPa psig)
- d. Aircraft connection pressure (kPa psig)
- e. Aircraft connection humidity ratio (kg/kg gr/lb)
- f. Pre-conditioned air unit discharge air mass flow rate (kg/min lb/min)
- g. Aircraft connection discharge air mass flow rate (kg/min lb/min)
- h. Ambient temperature (degrees C F)
- i. Ambient humidity (kg/kg gr/lb)

3.5.1.3 Instruments

List the instruments used to measure performance data. Include in the listing each instrument's unique identification number, calibration date, and calibration expiration date. Instruments must have been calibrated within one year of the date of use in the field, and calibration must be traceable to the measuring standards of the National Institute of Standards and Technology. All instrumentation must bear a valid NIST traceable calibration certificate during field work and during government acceptance testing.

3.5.2 Notification of Pre-Conditioned Air System Performance Testing

Notify the Contracting Officer in writing at least 30 calendar days in advance of all acceptance tests. Notification must include PCA System Certificate of Completion. If partial performance testing is necessary because outdoor conditions are not within the required range, include the anticipated endurance test dates in the Notification of PCA Performance Testing. Test each unit for Contracting Officer acceptance in accordance with the approved test plan.

3.5.3 Performance Testing

Conduct the field testing in compliance with the Contracting Officer approved performance test plan, and in accordance with additional testing requirements specified herein. Record the required data using the test reporting forms approved of the approved field test plan.

Conduct the endurance test for each PCA for a continuous 4-hour test period. If a unit shuts down before the continuous 4-hour test period is completed, the test must be started again and run for the required duration. If any performance variable measured at the aircraft connection falls outside of the acceptable range in paragraph titled PERFORMANCE REQUIREMENTS for more than one measurement interval, the endurance test will be failed. Record the cool down time required for air measurements

to be within the required performance parameters. If the cool down time exceeds 30 minutes, the test will be failed. If the system experiences any failures during the endurance test portion of the test, repair the system and repeat the endurance test portion until the system operates continuously and without failure for the specified endurance test period.

3.5.4 Performance Test Report

Within 30 calendar days after acceptable completion of testing, submit each test report for the review and approval of the Contracting Officer. Use the test reporting forms approved in the Performance Test Plan. Final test report forms must be typed, including data entries and remarks. Completed test report forms for each PCA must be reviewed, approved, and signed by the Contractor's test director and the QC manager.

3.5.5 Deficiency Resolution and Re-testing

Deficiencies identified during the tests must be corrected in compliance with the contract requirements and retested as specified in the paragraph titled ACCEPTANCE TESTS. Any deficiencies observed must be corrected by the Contractor without cost to the Government.

3.6 ADJUSTING AND CLEANING

Wipe equipment clean, removing all traces of oil, dust, dirt, or paint spots. Provide temporary filters for all fans that are operated during construction, and install new filters after all construction dirt has been removed from the building. Maintain the system in this clean condition until final acceptance.

Bearings must be properly lubricated with oil or grease as recommended by the manufacturer. Belts must be tightened to proper tension. Control valves and other miscellaneous equipment requiring adjustment must be adjusted to setting indicated or directed. Fans must be adjusted to the speed indicated by the manufacturer to meet specified conditions.

3.7 CLOSEOUT ACTIVITIES

3.7.1 Operation and Maintenance Manual

Submit operation and maintenance manuals meeting requirements of Section 01 78 23 OPERATION AND MAINTENANCE DATA and 01 78 24.00 20 FACILITY ELECTRONIC OPERATION AND MAINTENANCE SUPPORT INFORMATION (eOMSI) no later than 30 calendar days before contract completion. Provide recommended spare parts listing for each assembly or component.

3.7.2 Training Plan

Furnish the services of competent instructors to give full instruction to the designated Government personnel in the adjustment, operation, and maintenance, including pertinent safety requirements, of the PCA system in accordance with requirements of Section 01 78 23 OPERATION AND MAINTENANCE DATA. Instructors must be thoroughly familiar with all parts of the installation and instructed in operating theory as well as practical operation and maintenance work. Submit a training plan for the instruction course including instructor's qualifications and certifications for approval.

Conduct a training course as designated by the Contracting Officer. The

training period must consist of a maximum of 16 hours of normal working time and start after the system is functionally completed but prior to final acceptance tests. The field posted instructions must cover all of the items contained in the approved operation and maintenance manuals as well as demonstrations of routine maintenance operations. When significant changes or modifications in the equipment or system are made under the terms of the contract, provide additional instruction to acquaint the operating personnel with the changes or modifications.

-- End of Section --