

Pragma-F
Ik = 6 KA
750 x 1100 x 182

VOOR VERVOLG ZIE TEKENING L5-0a

VOOR VERVOLG ZIE TEKENING L5-0c

L5-0

21	16A		12xWCD	2400 VA
22	16A		9xWCD	1800 VA
23	16A		6xWCD	1200 VA
24	16A	 30mA	8xWCD	1600 VA
25	16A	 30mA	8xWCD	1600 VA
26	16A		10xWCD COMPUTERS	2000 VA
27	16A		BOILER IN T021	2400 VA
28	16A		BOILER IN T023	2400 VA
29	16A		RESERVE	VA
30	16A		7xWCD	1400 VA
31	16A		7xWCD	1400 VA
32	16A		7xWCD	1400 VA
33	16A		5xWCD	1000 VA
34	16A		PATCHKAST	VA
35	16A		BOILER T041A	5200 VA
36	16A		RESERVE	VA
37	16A		RESERVE	VA
38	16A		RESERVE	VA
39	16A		RESERVE	VA
40	16A		RESERVE	VA
41	16A		VOEDING KAST NL-5	1500 VA
42	16A		KLRACHT WCD IN T043	1500 VA
43	16A		BOILER IN T041A	5200 VA
44	16A		RESERVE	VA
45	16A		RESERVE	VA
46	16A		RESERVE	VA

INDIEN NIET NADER AANGEGEVEN
KRACHT GROEPEN 5x2,5mm2
LICHT GROEPEN 3x2,5mm2



GRAAFSCHAP COLLEGE & CENTRUM VAKOPLEIDING, DOETINCHEM		Blad: E-22/18b
Getekend : JK	Projekt nr.: 95-001	WERKPLAATS BEG. GROND
Datum : 04-11-96	Gewijzigd : 16-02-98	LICHTKAST L5-0b

REVISIE