

Energy information per hospital														
New equipment energy requirements (kVA)	Arua	Fort Portal	Gulu	Hoima	Jinja	Kabale	Lira	Masaka	Mbale	Mbarara	Moroto	Mubende	Naguru	Soroti
A&E	0	6	0	6	6	6	0	6	6	6	5	4	6	6
Imaging	153	260	225	260	260	260	153	260	332	332	260	260	260	260
Total for OT	5	8	4	8	8	6	6	6	8	5	8	5	8	8
ICU / HDU	5	8	5	8	1	8	5	8	8	1	8	8	8	8
NICU	12	12	6	12	12	12	12	12	12	12	12	12	12	12
Total for maternity	11	11	5	11	11	11	11	11	11	11	11	11	11	11
Central Sterilisation Department	49	97	49	48	97	1	48	49	97	97	49	48	97	97
Mains power requirements (kVA) per Hospital	237	402	295	353	395	305	237	353	474	465	354	350	402	402

Power Supply Upgrade as part of DRIVE project

Transformer	✓	✓	✓	✓	✓		✓	✓				✓		✓
Voltage Regulator	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓
Switchgear		✓	✓	✓	✓	✓	✓	✓				✓		✓