



ADVISEURS

Project: **Stadhuis Vlaardingen**
Projectnr.: **71020A**
Onderwerp: **Koel- en verwarmingsvermogen per regelzone**
Datum: **2-7-2012**

Verdieping	Regelzone Nr.	Koelvermogen Watt/m2 vloer	Verwarmingsvermogen Watt/m2 vloer	Toelichting
Begane Grond				
	1	33	91,5	
	2	42	89	
	3	44	110	
	4	31	64	
	5	44	110	
	6	27	64	vermogen concentreren in Cockpit
	7	27	64	
	8	37	80	
	9	44	117	
	38	46	97	
	39	31	93	
	10	18	26	
	11	20	26	
1e verdieping				
	12	43	103	
	13	39	69	
	14	43	102	
	15	33	56	
	16	46	101	
	17	31	56	
	18	43	108	
	19	41	75	
	20	47	108	
	21	38	63,5	
2e verdieping				
	22	34	89	
	23	38	89,5	
	24	36	57	
	25	36	57	
3e verdieping				
	26	38	63,5	
	27	-	90	VAV-luchtkoeling
4e verdieping				
	29	45	109	
	30	43	75,5	
	31	45	108	
	32	37	62,5	
	33	45	108	
	34	31	62	vermogen concentreren in teamruimte
	35	31	62	
	36	44	103	
	37	38	64	
	28	24	32,4	