

Stadhuis Hoorn

Metingen aardlekbeveiligingen

d.d. 07-03-2015

3L2 bouwdeel C 3e verdieping		
groep	aardlek mA	ms
16	22,5	7
17	21,0	29
18	19,5	49
19	22,5	48
20	24,0	27
21	22,5	27
22	18,0	34
23	21,0	26
24	22,5	27
25	24,0	26
26	24,0	26
27	22,5	26
29	24,0	27
30	21,0	29