SIEMENS

Hotelschool The Hague

Soiling report

4/20/26 9:03 AM

1 - Brandmeldcentrale

Device customer tex	Device address pa	Operating years	Compensation level	Compensation value	Logical customer te	Logical add	Serial no. ("ID-Nr.")
OP720	Station 1/2/1/1/2	4.67	Normal	8%	2e Verdieping	91/	289FDC2
OP720	Station 1/2/1/5/2	4.67	Normal	12%	2e Verdieping Onderwijs	61/	289FDA6
FDM225/226	Station 1/2/1/6/1	---	---	---	2e Verdieping Onderwijs	62/	26A210D
OP720	Station 1/2/1/10/2	4.67	Normal	9%	2e Verdieping Onderwijs	61/	289FDC8
OP720	Station 1/2/1/12/2	4.67	Normal	8%	2e Verdieping	95/	28AD89B
OP720	Station 1/2/1/13/2	4.67	Normal	11%	2e Verdieping Connecti	63/	28B63BC
OP720	Station 1/2/1/14/2	4.67	Normal	11%	2e Verdieping Connecti	63/	28AD310
FDM225/226	Station 1/2/1/22/1	---	---	---	2e Verdieping Connecti	64/	2679239
OP720	Station 1/2/1/32/2	4.67	Normal	12%	2e Verdieping Connecti	63/	289FDDC
OP720	Station 1/2/1/33/2	4.67	Normal	9%	2e Verdieping	97/	29EE3F5
OP720	Station 1/2/1/36/2	4.67	Normal	15%	1e Verdieping	97/	287834C
OP720	Station 1/2/1/37/2	4.67	Normal	12%	1e Verdieping Connecti	53/	2868E7F
FDM225/226	Station 1/2/1/47/1	---	---	---	1e Verdieping Connecti	54/	26A21FC
OP720	Station 1/2/1/55/2	4.67	Normal	12%	1e Verdieping Connecti	53/	28ADAE9
OP720	Station 1/2/1/57/2	4.67	Normal	6%	1e Verdieping	95/	28B6344
FDM225/226	Station 1/2/1/65/1	---	---	---	1e Verdieping Onderwijs	52/	26A21C2
OP720	Station 1/2/1/68/2	4.67	Normal	12%	1e Verdieping Onderwijs	51/	28ADAC8
OP720	Station 1/2/1/73/2	4.67	Normal	9%	1e Verdieping	91/	289FDE9
OP720	Station 1/2/2/1/2	4.67	Normal	12%	4e Verdieping	91/	28B634C
OP720	Station 1/2/2/5/2	4.67	Normal	12%	4e Verdieping Onderwijs	81/	289FB31
FDM225/226	Station 1/2/2/8/1	---	---	---	4e Verdieping Onderwijs	82/	26792F8
OP720	Station 1/2/2/13/2	4.67	Normal	14%	4e Verdieping Onderwijs	81/	2868E6E
OP720	Station 1/2/2/14/2	4.67	Normal	12%	4e Verdieping	95/	28B63A3
OP720	Station 1/2/2/16/2	4.67	Normal	9%	4e Verdieping Connecti	83/	29EE414
OP720	Station 1/2/2/17/2	4.67	Normal	9%	4e Verdieping Connecti	83/	28AD88E
FDM225/226	Station 1/2/2/27/1	---	---	---	4e Verdieping Connecti	84/	26792FB
OP720	Station 1/2/2/37/2	4.67	Normal	12%	4e Verdieping Connecti	83/	286E49E
OP720	Station 1/2/2/38/2	4.67	Normal	9%	4e Verdieping	97/	289FEFF
OP720	Station 1/2/2/39/2	4.67	Normal	9%	4e Verdieping	97/	29C6801
OOH740	Station 1/2/2/40/2	4.67	Normal	6%	3e Verdieping MER ruim	73/	5DFFE53
OOH740	Station 1/2/2/40/4	4.67	Normal	6%	---	---	5DFFE53
OOH740	Station 1/2/2/42/2	4.67	Normal	6%	3e Verdieping MER ruim	73/	5DFFF50
OOH740	Station 1/2/2/42/4	4.67	Normal	6%	---	---	5DFFF50
OP720	Station 1/2/2/43/2	4.67	Normal	9%	3e Verdieping	97/	289FB8C
OP720	Station 1/2/2/44/2	4.67	Normal	12%	3e Verdieping Connecti	71/	289FDC6
FDM225/226	Station 1/2/2/54/1	---	---	---	3e Verdieping Connecti	72/	292337D
OP720	Station 1/2/2/62/2	4.67	Normal	12%	3e Verdieping Connecti	71/	28B610A
OP720	Station 1/2/2/63/2	4.67	Normal	12%	3e Verdieping Connecti	71/	28B63B7
OP720	Station 1/2/2/64/2	4.67	Normal	12%	3e Verdieping	95/	28ADB55
FDM225/226	Station 1/111/1/2/1	---	---	---	Begane Grond Restaura	34/	29FBB93
OP720	Station 1/111/1/3/2	4.67	Normal	9%	Begane Grond Keuken/I	35/	29C9FB4
OP720	Station 1/111/1/6/2	4.67	Normal	6%	Begane Grond Keuken/I	35/	2829987
FDM225/226	Station 1/111/1/7/1	---	---	---	Begane Grond Keuken/I	36/	2607EDA
OP720	Station 1/111/1/9/2	4.67	Normal	9%	Begane Grond Keuken/I	35/	29C69B5
OP720	Station 1/111/1/10/2	4.67	Normal	8%	Begane Grond Keuken/I	35/	28297C6
OP720	Station 1/111/1/11/2	4.67	Normal	11%	Begane Grond Keuken/I	35/	2829779
OP720	Station 1/111/1/14/2	0.67	Normal	9%	Begane Grond Keuken/I	35/	73B7E6A
OP720	Station 1/111/1/15/2	4.67	Normal	9%	Begane Grond Keuken/I	35/	29C69FD
OP720	Station 1/111/1/16/2	0.67	Normal	11%	Begane Grond Keuken/I	35/	73B7DF8
OP720	Station 1/111/1/21/2	4.67	Normal	9%	Begane Grond	91/	2829984
OP720	Station 1/111/1/22/2	4.67	Normal	6%	Begane Grond Keuken/I	35/	2829781
FDM225/226	Station 1/111/1/26/1	---	---	---	Begane Grond Restaura	34/	29FBBB9
FDM225/226	Station 1/111/1/28/1	---	---	---	Begane Grond Restaura	34/	2607ED0
OP720	Station 1/111/1/30/2	4.67	Normal	11%	Begane Grond Horeca \	31/	283C7A1
FDM225/226	Station 1/111/1/32/1	---	---	---	Begane Grond Horeca \	32/	2607EDB
FDM225/226	Station 1/111/1/37/1	---	---	---	Begane Grond Horeca \	32/	2624066
FDM225/226	Station 1/111/1/41/1	---	---	---	Begane Grond Horeca \	32/	2623FC6
OP720	Station 1/111/1/44/2	4.67	Normal	9%	Begane Grond Horeca \	31/	29C681F
FDM225/226	Station 1/111/1/47/1	---	---	---	Begane Grond Restaura	34/	28ED6E0

FDM225/226	Station 1/111/1/54/1	---	---		---	Begane Grond Keuken/l	36/	28EEEBC
OP720	Station 1/111/1/55/2	4.67	Normal		8%	Begane Grond Keuken/l	35/	29C6817
OP720	Station 1/111/1/56/2	4.67	Normal		11%	Begane Grond Keuken/l	35/	287A739
OP720	Station 1/111/1/57/2	4.67	Normal		9%	Begane Grond Keuken/l	35/	283CA3F
OP720	Station 1/111/1/58/2	4.67	Normal		6%	Begane Grond Le Cafe	37/	2868E61
OP720	Station 1/111/1/59/2	4.67	Normal		12%	Begane Grond Le Cafe	37/	287AAFB
OP720	Station 1/111/1/60/2	4.67	Normal		9%	Begane Grond Le Cafe	37/	287AADF
OP720	Station 1/111/1/61/2	4.67	Normal		12%	Begane Grond	95/	286E497
FDM225/226	Station 1/111/1/65/1	---	---		---	Begane Grond Le Cafe	38/	2923384
OP720	Station 1/111/1/72/2	4.67	Normal		11%	Begane Grond Le Cafe	37/	287AAD6
OP720	Station 1/111/1/74/2	4.67	Normal		12%	Begane Grond	97/	286E4A8
OP720	Station 1/111/1/75/2	4.67	Normal		11%	Begane Grond	97/	28ADADE
FDM225/226	Station 1/111/1/76/1	---	---		---	Begane Grond Le Cafe	38/	26792F2
OP720	Station 1/111/1/77/2	4.67	Normal		9%	Begane Grond Auditoriu	39/	2829965
FDM225/226	Station 1/111/1/78/1	---	---		---	Begane Grond Auditoriu	40/	264F012
OP720	Station 1/111/1/80/2	4.67	Normal		9%	Begane Grond Auditoriu	39/	282979C
OP720	Station 1/111/1/81/2	4.67	Normal		9%	Begane Grond Auditoriu	39/	282E94C
OP720	Station 1/111/1/83/2	4.67	Normal		12%	Begane Grond Auditoriu	39/	282EA19
OP720	Station 1/111/1/84/2	4.67	Normal		9%	Begane Grond Auditoriu	39/	283B039
OP720	Station 1/111/1/85/2	4.67	Normal		11%	Begane Grond Auditoriu	39/	283B02B
OP720	Station 1/111/1/86/2	4.67	Normal		11%	Begane Grond Auditoriu	39/	2829736
OP720	Station 1/111/1/87/2	4.67	Normal		9%	Begane Grond Auditoriu	39/	283CA3E
OP720	Station 1/111/1/88/2	4.67	Normal		12%	Begane Grond Auditoriu	39/	283B04B
FDM225/226	Station 1/111/1/90/1	---	---		---	Begane Grond Auditoriu	40/	264F01B
OP720	Station 1/111/1/93/2	4.67	Normal		9%	Begane Grond Auditoriu	39/	29EE21C
OP720	Station 1/111/1/95/2	4.67	Normal		11%	Begane Grond Auditoriu	39/	29EE248
OP720	Station 1/111/1/96/2	4.67	Normal		8%	Begane Grond Auditoriu	39/	29EE226
OP720	Station 1/111/1/98/2	4.67	Normal		9%	Begane Grond Auditoriu	39/	29C680E
OP720	Station 1/111/1/99/2	4.67	Normal		9%	Begane Grond Auditoriu	39/	283C7CE
OP720	Station 1/111/1/100/2	4.67	Normal		9%	Begane Grond Auditoriu	39/	283C7E8
FDM225/226	Station 1/111/1/102/1	---	---		---	Begane Grond Auditoriu	40/	2607ED3
FDM225/226	Station 1/111/1/103/1	---	---		---	Begane Grond Auditoriu	40/	26A21C0
OP720	Station 1/112/1/2/2	4.67	Normal		12%	Souterrain	97/	287AADC
OP720	Station 1/112/1/5/2	4.67	Normal		9%	Souterrain Auditorium	19/	29C6808
OP720	Station 1/112/1/6/2	4.67	Normal		9%	Souterrain Auditorium	19/	28B60E8
OP720	Station 1/112/1/7/2	4.67	Normal		9%	Souterrain Auditorium	19/	29EE433
OP720	Station 1/112/1/16/2	4.67	Normal		9%	Souterrain Auditorium	19/	2829768
OP720	Station 1/112/1/17/2	4.67	Normal		12%	Souterrain Auditorium	19/	283B2EF
OP720	Station 1/112/1/18/2	4.67	Normal		8%	Souterrain Auditorium	19/	29EE40D
FDM225/226	Station 1/112/1/20/1	---	---		---	Souterrain Auditorium	20/	2625D60
OP720	Station 1/112/1/21/2	4.67	Normal		9%	Souterrain Auditorium	19/	282994D
OP720	Station 1/112/1/25/2	4.67	Normal		9%	Souterrain Auditorium	19/	29C69AF
OP720	Station 1/112/1/29/2	4.67	Normal		9%	Souterrain Mediatheek +	17/	28782F6
FDM225/226	Station 1/112/1/33/1	---	---		---	Souterrain Mediatheek +	18/	26792F3
OP720	Station 1/112/1/43/2	4.67	Normal		11%	Souterrain Mediatheek +	17/	28ADAE2
OP720	Station 1/112/1/45/2	4.67	Normal		12%	Souterrain	95/	28AD557
OP720	Station 1/112/1/46/2	4.67	Normal		11%	Souterrain Mediatheek +	17/	289FDD2
OP720	Station 1/112/1/47/2	4.67	Normal		9%	Souterrain Mediatheek +	17/	29EE438
OP720	Station 1/112/1/49/2	4.67	Normal		9%	Souterrain Collegezalen	13/	282EA23
FDM225/226	Station 1/112/1/53/1	---	---		---	Souterrain Technische D	16/	2625675
FDM225/226	Station 1/112/1/62/1	---	---		---	Souterrain Collegezalen	14/	23F25BC
FDM225/226	Station 1/112/1/71/1	---	---		---	Souterrain Collegezalen	14/	2665E5A
FDM225/226	Station 1/112/1/77/1	---	---		---	Souterrain Collegezalen	14/	2607E7A
OP720	Station 1/112/1/80/2	4.67	Normal		9%	Souterrain Collegezalen	13/	29C6806
OP720	Station 1/112/1/82/2	4.67	Normal		9%	Souterrain Computerzal	11/	282979A
OP720	Station 1/112/1/84/2	4.67	Normal		11%	Kelder + Werkplaats	1/	289FDDB
OP720	Station 1/112/1/85/2	4.67	Normal		12%	Kelder + Werkplaats	1/	28B63BF
OP720	Station 1/112/1/87/2	4.67	Normal		12%	Kelder + Werkplaats	1/	28B634B
OP720	Station 1/112/1/88/2	4.67	Normal		9%	Kelder + Werkplaats	1/	29EE22F
OP720	Station 1/112/1/89/2	4.67	Normal		9%	Kelder + Werkplaats	1/	2DF23E4
OP720	Station 1/112/1/91/2	4.67	Normal		12%	Kelder + Werkplaats	1/	2DF23F2
OP720	Station 1/112/1/92/2	4.67	Normal		6%	Kelder + Werkplaats	1/	28B60DA
OP720	Station 1/112/1/93/2	4.67	Normal		9%	Kelder + Werkplaats	1/	289FDDD
OOH740	Station 1/112/1/95/2	4.67	Normal		6%	Kelder + Werkplaats	1/	5D48F98
OOH740	Station 1/112/1/95/4	4.67	Normal		6%	---	---	5D48F98
OOH740	Station 1/112/1/96/2	4.67	Normal		3%	Kelder + Werkplaats	1/	5D4E638
OOH740	Station 1/112/1/96/4	4.67	Normal		3%	---	---	5D4E638
FDM225/226	Station 1/112/1/99/1	---	---		---	Souterrain Computerzal	12/	260B552

Compensation value: - Normal -> no action required - 100%: Warning -> change of detector recommended (detector still functional) - 150%: Maximum -> change of detector required (alarming still possible but detection possibly restricted)